
# A03-A04

# Electronic level controls with probes for conductive liquids

### EA18 Identification probe in AISI 303 stainless steel.

SUITABLE FOR WELLS AND TANKS UNDER PRESSURE AND/OR FOR HIGH TEMPERATURES.

Dimensions (mm)



#### **FEATURES**

Maximum operating pressure: 10 bar. Maximum temperature: 160 ° C. Male connection G 3/8".

#### **INSTALLATION**

Connection between the probe and the level control is realized through a single-pole flexible cable (not supplied). Electrode probe is not supplied as well.

#### **ACCESSORIES**


code 2013347 Stainless steel electrode AISI 303 - 1 m length. code 2013348 Stainless steel electrode AISI 303 - 2 m length.

# EA19 Ballasted PVC probe with electrode

SUITABLE FOR WELLS, STORAGE TANKS AND RESERVOIRS FOR IRRIGATION.







#### **FEATURES**

Operation at atmospheric pressure. Maximum temperature: 80°C.

Stainless steel electrode AISI 303 (included).

Cable gland G1/4".

Connection cable 1x1,5mm² (not included).

#### INSTALLATION


Connection between the probe and the level control is realized through a single-pole flexible cable (not supplied).

## EA20 Stainless steel electronic probe AISI 303

SUITABLE FOR WELLS AND TANKS UNDER PRESSURE AND/OR FOR HIGH TEMPERATURES.



imensions (mm)



#### **FEATURES**

Maximum operating pressure: 35 bar. Maximum temperature: 250°C. Male connection G3/8".

#### **INSTALLATION**

Connection between the probe and the level control is realized through a single-pole flexible cable (not supplied). Electrode probe is not supplied as well.


#### **ACCESSORIES**

code 2013347 Stainless steel electrode AISI 303 - 1 m length. code 2013348 Stainless steel electrode AISI 303 - 2 m length.

# EA21 Ballasted PVC probe with electrode

SUITABLE FOR WELLS. STORAGE TANKS AND RESERVOIRS FOR IRRIGATION.





#### **FEATURES**

Operation at atmospheric pressure. Maximum temperature: 50°C. 6m cable length (electrode is not included). Stainless steel electrode AISI 316 (included).

#### INSTALLATION