HIOKI

BATTERY HITESTER 3554

Component measuring instruments



Get a Complete Diagnosis of UPS Batteries with a Single Device







The New Standard for Assessing **Deterioration of Lead-acid Batteries**

Repeated recharging of a secondary battery can lead to battery deterioration and increase its internal resistance. Problems can intensify when there is a short-circuit in the internal cell leading to voltage drop, overheating and complete battery malfunction. Worst of all, these problems can cause life-threatening fires and other accidents.

HANDS FREE Data Capture Allows You to Focus on the Testing



Quickly Download Data to a PC via USB Interface - Effortlessly Manage Using Table - [sample.csv *] Bundled Software




Next table No.

Tough Against Noise Plus Wide 60V Range

Trying to measure UPS backup batteries while they are still being used naturally brings about noise coming from the battery's inverter or rectifying circuit. The enhanced measurement current in the 3554 plus fortified circuit design, added with the Averaging Function to handle batteries that have fluctuating measurement values no matter how steady you hold the probe makes the battery tester extra resistant against the adverse effects of noise.

Three-rank rating of battery state: Pass, Warning or Fail

Assessment is based on a 6-way combination of comparisons against upper and lower resistance limits and a voltage threshold. Immediately see the judgement result on the bright LCD and beep on your choice of PASS or WARNING/FAIL.



Wide Selection of Tough and Versatile Test Probes The standard F



The Advantages of 4-Terminal Measurement


The Quality of Your Test Lead CAN Make a Difference

When measuring certain batteries such as leadacid cells, the resulting measurement value may differ depending on the test leads used to conduct the measurement. This difference is due to the shape of the probe tip as well as the dimensions of the 4-terminal test leads used for measurement. However, despite a difference in value given by different test leads, it is safe to assume that each specific value reflects the correct value obtainable by the respective test leads.

Based on this principle, when diagnosing battery deterioration in a time series, it is particularly important to use test leads having the same tip shape

and dimensions in order to maintain measurement consistency. The difference in the measurement values

The difference in the measurement values obtained by different test leads is a physical phenomenon caused by the difference in distance between the SOURCE and SENSE pins of the test leads. This is more significant when the battery terminal contains a resistance higher than the internal resistance of the battery under test. The figure on the right demonstrates how even minute physical differences between the SOURCE and SENSE pins for two types of test leads can affect the detected voltage level of the battery.



Specifications

Basic Specifications

Measurement items :	Resistance (AC four-terminal method), voltage, temperature (platinum temperature sensor, only when using 9460 leads)		
Display :	LCD		
LCD All Segments Displayed	DADJ AMEND (***) APS **** AVG DATE NEMDON: BASS COMP N: BASS SET O O		
	-8.8.8.8∜ 8.8:8.8 c		
	COMP PASS WARNING FAIL		
	COME PASS WARNING FAIL		
Sampling rate :	Once per second		
Averaging Function :	OFF, 4, 8, or 16 times		
Input overflow	[OF] is displayed		
Constant current fault	[] is displayed		
detection			
Open-circuit terminal : voltage	5 VMax		
Auto power off :	Auto power off after 10 minutes unless during data transmission		
Comparator Settings :	First and second resistance limits, and lower voltage limit		
Number of Comparator : Settings	200 Sets		
Comparator Output :	LCD display of PASS, WARNING, or FAIL. Select beeper to sound on PASS/WARNING or FAIL.		
Operating temperature : and humidity	0 to 40°C (32°F to 104°F), 80% rh or less (no condensation)		
Absolute maximum : input voltage	60V DC, No AC input allowed		
Withstand voltage :	Between input terminals and output terminals (including EXT. HOLD/MEMO, and USB terminals): 1.5 kV AC rms for 15 seconds		
Maximum rated power : consumption	2 VA		
Continuous operating : time	Approx. 10 hours (When using alkaline batteries; may vary depending on conditions of use)		
Power supply :	AA (LR6) Alkaline Batteries x 8		



Measurement Accuracy (Guaranteed Accuracy Period: 1 Year)

Guaranteed Accuracy : 23°C± 5°C (73°F± 9°F), non-condensating, after zeroadjustment, warm-up time not required Resistance Measurement Temperature coefficient : ±0.01 %rdg.±0.8 dgt./°C

Measurement current frequency : 1 kHz±30 Hz Measurement current reliability : ±10%

Conditions

Range	Max. display	Resolution	Measurement Current	Accuracy
$3\mathrm{m}\Omega$	3.100 mΩ	1μΩ	150 mA	±1.0% rdg. ±8 dgt.
30 mΩ	31.00mΩ	10 μΩ	150 mA	
$300 \text{ m}\Omega$	310.0 mΩ	100 μΩ	15 mA	±0.8% rdg. ±6 dgt.
3Ω	3.100 Ω	1 mΩ	1.5 mA	

The thresholds for determining the pass/fail condition of a battery depends on the specifications and standards of the battery manufacturer, battery type, capacity, etc. It is

important and necessary to always conduct battery testing against the internal resistance and

terminal voltage of a new or reference battery. In some cases, it may be diffcult to determine

the deterioration state of traditional open type (liquid) lead-acid or alkaline batteries which

demonstrate smaller changes in internal resistance than sealed lead acid batteries.

Voltage Measurement

CSV format)

Application

Temperature coefficient : ±0.005% rdg. ±0.5 dgt. /°C

	Range	Max. display	Resolution	Accuracy
	6 V	±6.000 V	1 mV	
	60 V	±60.00 V	10 mV	±0.08% rdg. ±6 dgt.
1				

data from 3554, initialize the 3554, make clock settings 3554 to PC: transfer data stored in memory (save files on PC in

Temperature Measurement

Measurement Range	Resolution	Accuracy			
-10°C to 60°C	0.1°C	±1.0°C			

Options

Bundled with the standard 3554 PIN TYPE LEAD 9465-10 ZERO ADJUSTMENT BOARD 9454

CLIP TYPE LEAD WITH TEMPERATURE SENSOR 9460 PIN TYPE LEAD 9772 REMOTE CONTROL SWITCH 9466 LARGE CLIP TYPE LEAD 9467 TIP PIN 9465-90 (to replace the tip on Model 9465-10) TIP PIN 9772-90 (to replace the tip on Model 9772)

Note: Company names and Product names appearing in this catalog are trademarks or registered trademarks of various companies

HIOKI E. E. CORPORATION

To Our Valued Customers:



HEADQUARTERS

81 Koizumi, Ueda, Nagano, 386-1192, Japan TEL +81-268-28-0562 FAX +81-268-28-0568 http://www.hioki.com / E-mail: os-com@hioki.co.jp TEL +65-6634-7677 FAX +65-66

TEL +91-124-6590210 FAX +91-124-6460113 E-mail: hioki@hioki.in TEL +65-6634-7677 FAX +65-6634-7477 E-mail: info-sg@hioki.com.sg

HIOKI USA CORPORATION TEL +1-609-409-9109 FAX +1-609-409-9108 http://www.hiokiusa.com / E-mail: hioki@hiokiusa.com

HIOKI KOREA CO., LTD. TEL +82-42-936-1281 FAX +82-42-936-1284 E-mail: info-kr@hioki.co.jp

All information correct as of Jan. 1, 2015. All specifications are subject to change without notice.